



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3303058-118-2023

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: KRISTIN LOELLEN BROWN DATE: 11/13/2023 AT 12:40PM

WORK ORDER(S): 3303058 3303033

EST DATE AND TIME SSO BEGAN: 11/13/2023 11:00AM DURATION: 1.83 HRS
DATE AND TIME SSO ENDED: 11/13/2023 12:50PM

SOURCE-OVERFLOWING MH MH04008227 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 12719 BUCKHARDT CT 20735
COUNTY/PAGE/GRID: P 5881 H06 TOWN/CITY: CLINTON

CAUSE: DEBRIS EST OVERFLOW VOLUME: 55 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 227M OVERFLOWING APPROXIMATELY
0.5GPM ONTO A GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM
MANHOLE 226M TO 227M, A TOTAL OF 339FT, AND HIT AND RELIEVED A GRAVEL
OBSTRUCTION AT 154FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

THE EVENT WAS REPORTED AS 12716 BUCKHARDT COURT ON THE END OF EVENT
NOTIFICATION.

SIGNS POSTED: 4 POST DATE: 11/13/2023