



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3303627-118-2023

MDE OFFICIAL CONTACTED: EVELYN STRAVOU

DATA CALLED IN BY: MARVIN BAILEY DATE: 11/15/2023 AT 03:40PM

WORK ORDER(S): 3303627 3303613

EST DATE AND TIME SSO BEGAN: 11/15/2023 12:58PM DURATION: 3.03 HRS
DATE AND TIME SSO ENDED: 11/15/2023 04:00PM

SOURCE-OVERFLOWING MH MH05018015 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 4403 ELM ST 20815
COUNTY/PAGE/GRID: M 5407 F03 TOWN/CITY: CHEVY CHASE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 182 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 015M OVERFLOWING AT 1GPM INTO THE
SURROUNDING WOODED AREA AND INTO A NEARBY CREEK NAMED COQUELIN RUN.
THE CREW JETTED A TOTAL OF 400' FROM MANHOLE 014M TO MANHOLE 015M AND
RELIEVED GREASE AND WIPES AT 275' TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME FLUSHED BACK INTO MANHOLE
RAKED AREA

SOLIDS WERE FLUSHED BACK INTO THE MANHOLE AND THE AREA WAS CLEANED
UP.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

ORIGINALLY REPORTED AS 4105 EAST WEST HWY

SIGNS POSTED: 4 POST DATE: 11/15/2023