



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3306278-118-2023

MDE OFFICIAL CONTACTED: CHRISTY WAGNER

DATA CALLED IN BY: JAMES V MALLORY

DATE: 11/30/2023 AT 02:45PM

WORK ORDER(S): 3306278 3306275

EST DATE AND TIME SSO BEGAN: 11/30/2023 12:30PM DURATION: 10.25 HRS

DATE AND TIME SSO ENDED: 11/30/2023 10:45PM

SOURCE-OVERFLOWING MH MH18053274 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 1901-39 BROOKS DR 20743

COUNTY/PAGE/GRID: P 5650 E02 TOWN/CITY: FORESTVILLE

CAUSE: DEBRIS EST OVERFLOW VOLUME: 1,230 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 274M OVERFLOWING APPROXIMATELY 2GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO A NEARBY STORM DRAIN THAT OUTFALLS IN THE OXON RUN BASIN. THE CREW DISCOVERED LARGE ROCKS AND CONCRETE IN THE 37' DEEP MANHOLE AND WERE UNABLE TO RELIEVE THE BLOCKAGE. THE WSSC CONTRACTOR SET-UP A BYPASS, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

THE SEGMENT IS UNDER REPAIR AND THEREFORE CANNOT BE CCTV INSPECTED.

THE REPORT WILL BE UPDATED UPON COMPLETION OF REPAIRS AND CCTV INSPECTION.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME RAKED AREA

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 5514 ASHLEY PLACE.

SIGNS POSTED: 2 POST DATE: 12/01/2023