



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3308912-118-2023

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: 4581

DATE: 12/08/2023 AT 08:50AM

WORK ORDER(S): 3308912 3308896

EST DATE AND TIME SSO BEGAN: 12/08/2023 07:29AM DURATION: 3.52 HRS

DATE AND TIME SSO ENDED: 12/08/2023 11:00AM

SOURCE-OVERFLOWING MH MH15056030 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 13513 TEAKWOOD LN 20784

COUNTY/PAGE/GRID: M 5046 F02 TOWN/CITY: GERMANTOWN

CAUSE: WIPES EST OVERFLOW VOLUME: 422 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 030U OVERFLOWING APPROXIMATELY 2 GPM, GOING INTO A NEARBY STORM DRAIN THAT OUTFALLS IN SENECA CREEK. THE CREW JETTED FROM MANHOLE 114U TO 030U, A TOTAL OF 30', AND HIT AND RELIEVED RAGS AT 30', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE OVERFLOW ENTERED A STORM DRAIN AND REMAINING SOLIDS WERE FLUSHED BACK INTO THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 19739 TEAKWOOD CIRCLE.

SIGNS POSTED: 2 POST DATE: 12/08/2023