



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3310603-118-2023

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: BRANDON T MCCREA DATE: 12/19/2023 AT 08:59AM

WORK ORDER(S): 3310603

EST DATE AND TIME SSO BEGAN: 12/18/2023 02:38AM DURATION: 4.55 HRS  
DATE AND TIME SSO ENDED: 12/18/2023 07:11AM

SOURCE-OVERFLOWING MH MH04001020 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 13707 BAYTOMAC FARMS LN 20744  
COUNTY/PAGE/GRID: P 5881 A09 TOWN/CITY: FORT WASHINGTON

CAUSE: EXCESS FLOW EST OVERFLOW VOLUME: 500 GAL  
AT APPROXIMATELY 2:38AM ON 12/18/2023, A STAFF MEMBER AT THE PISCATAWAY WRRF DISCOVERED COLLECTION SYSTEM MANHOLE 020M WAS OVERFLOWING NEAR THE FACILITY DURING A HEAVY RAINFALL. ONCE EXCESS FLOW SUBSIDED, FACILITY STAFF OBSERVED THE MANHOLE WAS NO LONGER OVERFLOWING AT 7:11AM ON 12/18/2023. WSSC SECTION MANAGERS COLLABORATED TO EVALUATE THE FLOW RATE AND OVERFLOW EVIDENCE TO DETERMINE THE ESTIMATED VOLUME.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
WET WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME RAKED AREA

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES MISSED 24-HOUR REPORT DEADLINE

THIS EVENT WAS ORIGINALLY REPORTED AS 1101 SCHRADERS VIEW.

SIGNS POSTED: 1 POST DATE: 12/18/2023