



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3314562-109-2024

MDE OFFICIAL CONTACTED: AMANDA 153490

DATA CALLED IN BY: MARVIN BAILEY

DATE: 01/11/2024 AT 10:18PM

WORK ORDER(S): 3314562 3314489

EST DATE AND TIME SSO BEGAN: 01/11/2024 04:25PM DURATION: 3.17 HRS

DATE AND TIME SSO ENDED: 01/11/2024 07:35PM

SOURCE-REPAIR SEWER MAIN SS03018023 WATER BODY AFFECTED-BEAVERDAM BRANCH

CLOSEST STREET ADDRESS: 8911

BOLD ST

20774

COUNTY/PAGE/GRID: P 5531 D01

TOWN/CITY: SPRINGDALE

CAUSE: ROOTS AND WIPES

EST OVERFLOW VOLUME:

15 GAL

UPON ARRIVAL, THE CREW FOUND SEWAGE POOLED IN THE BACKYARD OF 8911

BOLD ST. MANHOLES 024M AND 025M WERE SURCHARGED. SEWAGE

EXFILTRATED THROUGH JOINTS IN SS03018023. THE CREW JETTED FROM

MANHOLE 020M TO 022M, AND HIT AND RELIEVED HEAVY ROOTS AND WIPES

AT 182', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME AND STRAW IN THE BACK YARD OF 8911 BOLD STREET.

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

SIGNS POSTED: 6 POST DATE: 01/12/2024