



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3316316-118-2024

MDE OFFICIAL CONTACTED: PATRICK KAMMAR

DATA CALLED IN BY: MARK A ALEXANDER DATE: 01/22/2024 AT 07:36PM

WORK ORDER(S): 3316316 3316266

EST DATE AND TIME SSO BEGAN: 01/22/2024 03:22PM DURATION: 3.30 HRS  
DATE AND TIME SSO ENDED: 01/22/2024 06:40PM

SOURCE-OVERFLOWING MH MH14123129 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 109 AZALEA CT 20774  
COUNTY/PAGE/GRID: P 5532 A08 TOWN/CITY: UPPER MARLBORO

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 198 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 129N OVERFLOWING APPROXIMATELY  
1GPM ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED  
FROM MANHOLE 128U TO 129N, A TOTAL OF 79', AND HIT AND RELIEVED A  
GREASE AND ROOTS OBSTRUCTION AT 5', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION  
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 01/23/2024