



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3328059-073-2024

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: JAMES V MALLORY

DATE: 02/09/2024 AT 11:15AM

WORK ORDER(S): 3328059 3327500

EST DATE AND TIME SSO BEGAN: 02/08/2024 01:00PM DURATION: 1.25 HRS
DATE AND TIME SSO ENDED: 02/08/2024 02:15PM

SOURCE-CLEAN OUT 00130616600 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 6122 OXON HILL RD 20745
COUNTY/PAGE/GRID: P 5765 D02 TOWN/CITY: OXON HILL

CAUSE: WIPES EST OVERFLOW VOLUME: 2 GAL
UPON THE WSSC CONTRACT PLUMBER'S ARRIVAL, THE PROPERTY LINE CLEANOUT WAS OVERFLOWING APPROXIMATELY 2GAL TOTAL, ON THE DRIVEWAY AND ENTERING INTO A STORM DRAIN IN THE OXON RUN BASIN. THE PLUMBER SNAKED THE CLEANOUT A TOTAL OF 120FT, AND HIT AND RELIEVED A WIPES BLOCKAGE AT 105FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 02/09/2024