



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3329373-118-2024

MDE OFFICIAL CONTACTED: CHRIS SHAFFNER

DATA CALLED IN BY: MARK A ALEXANDER DATE: 02/15/2024 AT 08:13PM

WORK ORDER(S): 3329373 3329362

EST DATE AND TIME SSO BEGAN: 02/15/2024 01:39PM DURATION: 2.35 HRS
DATE AND TIME SSO ENDED: 02/15/2024 04:00PM

SOURCE-OVERFLOWING MH MH14009034 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 9708 MUIRFIELD DR 20772
COUNTY/PAGE/GRID: P 5768 C10 TOWN/CITY: UPPER MARLBORO

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 71 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 034M OVERFLOWING 0.5 GPM, INTO A
NEARBY STORM DRAIN THAT OUTFALLS IN WESTERN BRANCH. THE CREW JETTED
FROM MANHOLE 029M TO 030U, A TOTAL OF 158', AND HIT AND RELIEVED A
HEAVY ROOT, GREASE, AND WIPES BLOCKAGE AT 80', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 9705 MUIRFIELD DRIVE.

SIGNS POSTED: 1 POST DATE: 02/15/2024