



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3336997-118-2024

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: MARVIN BAILEY

DATE: 03/08/2024 AT 02:30PM

WORK ORDER(S): 3336997 3336980

EST DATE AND TIME SSO BEGAN: 03/08/2024 11:11AM DURATION: 1.48 HRS

DATE AND TIME SSO ENDED: 03/08/2024 12:40PM

SOURCE-OVERFLOWING MH MH11027084 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 6015 S GATE DR 20748-6519

COUNTY/PAGE/GRID: P 5765 J02 TOWN/CITY: TEMPLE HILLS

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 178 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 084M OVERFLOWING APPROXIMATELY 2GPM ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A TRIBUTARY OF HENSON CREEK IN THE BROAD CREEK BASIN. THE CREW JETTED FROM MANHOLE 082U TO 084M, A TOTAL OF 74', AND HIT AND RELIEVED A GREASE AND WIPES OBSTRUCTION AT 40', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 03/08/2024