



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3337525-118-2024

MDE OFFICIAL CONTACTED: AMANDA GLASSMAN

DATA CALLED IN BY: DIARRA K MACKALL

DATE: 03/12/2024 AT 06:50PM

WORK ORDER(S): 3337525 3337479

EST DATE AND TIME SSO BEGAN: 03/12/2024 02:54PM DURATION: 6.10 HRS

DATE AND TIME SSO ENDED: 03/12/2024 09:00PM

SOURCE-OVERFLOWING MH MH14164242 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 9800 SUMMERTON DR 20721

COUNTY/PAGE/GRID: P 5531 F04 TOWN/CITY: MITCHELLVILLE

CAUSE: GREASE AND WIPES

EST OVERFLOW VOLUME: 366 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE'S 242U, 249U, 250M, 251M, AND 252M, EACH OVERFLOWING LESS THAN 1GPM INTO A NEARBY STORM DRAIN THAT OUTFALLS IN WESTERN BRANCH. THE CREW JETTED FROM MANHOLE 241U TO 242U, AND HIT AND RELIEVED A HEAVY GREASE/WIPES BLOCKAGE AT 8', TO END THE EVENT. THE TOTAL VOLUME FROM THIS EVENT IS 366 GALLONS.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 2117 SARAZAN WAY.

SIGNS POSTED: 2 POST DATE: 03/13/2024