



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3422943-071-2024

MDE OFFICIAL CONTACTED: #166237

DATA CALLED IN BY: SAMUEL C FRANK

DATE: 12/24/2024 AT 07:20PM

WORK ORDER(S): 3422943 3422936

EST DATE AND TIME SSO BEGAN: 12/24/2024 02:15PM DURATION: 1.25 HRS

DATE AND TIME SSO ENDED: 12/24/2024 03:30PM

SOURCE-FACILITY 00308099100 WATER BODY AFFECTED-PATUXENT RIVER

CLOSEST STREET ADDRESS: 6624 WEAVER CT 20707

COUNTY/PAGE/GRID: P 5168 H01 TOWN/CITY: LAUREL

CAUSE: OTHER EST OVERFLOW VOLUME: 6,000 GAL

UPON ARRIVAL, THE CREW FOUND A BROKEN WATER MAIN FLOWING INTO A STORM DRAIN AND INFILTRATING MANHOLES LEADING TO HILLSBORO WASTEWATER PUMPING STATION, CAUSING THE WET WELLS TO OVERFLOW ONTO THE GRASSY AREA AND INTO A STORM DRAIN THAT OUTFALLS INTO THE PATUXENT NORTH BASIN. THE CREW SHUT DOWN THE 6" WATER MAIN, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

DRY WEATHER

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 12 POST DATE: 12/24/2024