



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3441856-109-2025

MDE OFFICIAL CONTACTED: MS. EVELYN STRODMIRE

DATA CALLED IN BY: 4581

DATE: 02/26/2025 AT 02:35PM

WORK ORDER(S): 3441856 3441809

EST DATE AND TIME SSO BEGAN: 02/26/2025 10:44AM DURATION: 6.77 HRS
DATE AND TIME SSO ENDED: 02/26/2025 05:30PM

SOURCE-REPAIR SEWER MAIN 00350996500 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 19515 JERUSALEM CH TER 20837
COUNTY/PAGE/GRID: M 5044 F04 TOWN/CITY: POOLESVILLE

CAUSE: DEFECTIVE MATERIAL EST OVERFLOW VOLUME: 203 GAL
UPON ARRIVAL, THE CREW FOUND THE SERVICE FOR 19515 JERUSALEM CHURCH ROAD BROKEN, AND SEEPING OUT OF THE GROUND 0.5GPM, ONTO THE GRASSY AREA AND PAVEMENT ABOVE THE BREAK. THE CREW DUG UP THE SERVICE, AND RELACED 1' OF PVC PIPE AND ADDED 2 1-1/4" COUPLINGS, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THIS EVENT OCCURRED ON A FORCE MAIN, THEREFORE, NO CCTV INSPECTION CAN BE DONE FOR THIS EVENT.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
GRADING

THE CREW REMOVED, AND HAULED AWAY THE CONTAMINATED SOIL IN THE GRASSY AREA NEAR THE BROKEN SERVICE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 02/26/2025