



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3466943-109-2025

MDE OFFICIAL CONTACTED: EVELYN STAVRO

DATA CALLED IN BY: ELBE L DAVIS

DATE: 05/12/2025 AT 04:43PM

WORK ORDER(S): 3466943 3466896

EST DATE AND TIME SSO BEGAN: 05/12/2025 01:43PM DURATION: 13.28 HRS  
DATE AND TIME SSO ENDED: 05/13/2025 03:00AM

SOURCE-REPAIR SEWER MAIN SS29001096 WATER BODY AFFECTED-PATUXENT RIVER

CLOSEST STREET ADDRESS: 15700 ERWIN CT 20716  
COUNTY/PAGE/GRID: P 5413 C09 TOWN/CITY: MITCHELLVILLE

CAUSE: FORCE MAIN FAILURE EST OVERFLOW VOLUME: 1,594 GAL  
UPON ARRIVAL, THE WSSC INSPECTOR FOUND A BROKEN FORCE MAIN  
OVERFLOWING 2 GPM ONTO THE GRASSY AREA AROUND THE FORCE MAIN,  
AND INTO A STORM DRAIN THAT OUTFALLS INTO PATUXENT CENTER. A  
WSSC CONTRACTOR REPAIRED THE PIPE, TO END THE EVENT.

## IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION	NOTICEABLE ODOR
PUBLIC ACCESS	PUBLIC USE OBSERVED

## STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

## MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA NEAR THE BROKEN MAIN.

## NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT	PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES	

ORIGINALLY REPORTED AS 12601 EASTHAVEN LANE.

SIGNS POSTED: 12 POST DATE: 05/12/2025