



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3479551-073-2025

MOE OFFICIAL CONTACTED: JAMES LYONS

DATA CALLED IN BY: DIARRA K MACKALL

DATE: 06/22/2025 AT 02:56PM

WORK ORDER(S): 3479551 3479544

EST DATE AND TIME SSO BEGAN: 06/22/2025 11:16AM DURATION: 4.98 HRS  
DATE AND TIME SSO ENDED: 06/22/2025 04:15PM

SOURCE-CLEAN OUT 00097802300 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 8950 ANNAPOLIS RD 20706  
COUNTY/PAGE/GRID: P 5411 C07 TOWN/CITY: LANHAM-SEABROOK

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 299 GAL  
UPON ARRIVAL, THE CREW FOUND THE PROPERTY LINE CLEANOUT OVERFLOWING  
1 GPM, ONTO THE PAVEMENT, AND INTO A NEARBY STORM DRAIN THAT OUTFALLS  
INTO NORTHEAST BRANCH. A WSSC PLUMBER SNAKED FROM THE PROPERTY LINE  
CLEANOUT, A TOTAL OF 60', AND HIT AND RELIEVED AN UNKNOWN BLOCKAGE  
AT 30', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER NOTICEABLE ODOR  
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
VISIBLE SOLIDS REMOVED

THE CREW WASHED DOWN THE AREA AROUND THE CLEANOUT WITH  
DECHLORINATED WATER.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY  
MONTGOMERY CO MUNICIPALITIES

NO SIGNS WAS POSTED DUE TO THE LOCATION OF THE CLEANOUT. THIS EVENT  
WAS ORIGINALLY REPORTED AS 9002-A LANHAM-SEVERN ROAD.