



# WASHINGTON SUBURBAN SANITARY COMMISSION

## SANITARY SEWER OVERFLOW WRITTEN REPORT

3481551-118-2025

MOE OFFICIAL CONTACTED: EVELYN STAROU

DATA CALLED IN BY: 4581

DATE: 06/30/2025 AT 02:30PM

WORK ORDER(S): 3481551 3481543

EST DATE AND TIME SSO BEGAN: 06/30/2025 12:30PM DURATION: 1.58 HRS  
DATE AND TIME SSO ENDED: 06/30/2025 02:05PM

SOURCE-OVERFLOWING MH MH11012015 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 8205 WATERSIDE CT 20744  
COUNTY/PAGE/GRID: P 5764 F06 TOWN/CITY: FORT WASHINGTON

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 95 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 015M OVERFLOWING 1GPM ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 013U TO 015M, A TOTAL OF 108', AND RELIEVED GREASE AND WIPES AT 84', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

THE EVENT WAS ORIGINALLY REPORTED AS 8203 WATERSIDE COURT.

SIGNS POSTED: 2 POST DATE: 06/30/2025