



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3508689-118-2025

MDE OFFICIAL CONTACTED: CHUCK

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 10/01/2025 AT 03:00PM

WORK ORDER(S): 3508689 3508660

EST DATE AND TIME SSO BEGAN: 10/01/2025 01:06PM DURATION: 1.65 HRS

DATE AND TIME SSO ENDED: 10/01/2025 02:45PM

SOURCE-OVERFLOWING MH MH10020063 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 1355 E UNIVERSITY BLVD 20912

COUNTY/PAGE/GRID: M 5409 C03 TOWN/CITY: TAKOMA PARK

CAUSE: GREASE EST OVERFLOW VOLUME: 50 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 063N OVERFLOWING AT 0.5 GPM. THE CREW JETTED FROM MANHOLE 061M TO 062M, A TOTAL OF 30', AND RELIEVED GREASE AT 18', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE LIME
VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE AFFECTED AREA AND REMOVED ALL VISIBLE SOLIDS.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 3 POST DATE: 10/02/2025