



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3514744-118-2025

MDE OFFICIAL CONTACTED: FELIPE

DATA CALLED IN BY: PATRICIA A HILL

DATE: 10/22/2025 AT 05:30PM

WORK ORDER(S): 3514744 3514730

EST DATE AND TIME SSO BEGAN: 10/22/2025 03:19PM DURATION: 3.18 HRS

DATE AND TIME SSO ENDED: 10/22/2025 06:30PM

SOURCE-OVERFLOWING MH MH02044310 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 14334 BEAKER CT 20866  
COUNTY/PAGE/GRID: M 5168 A06 TOWN/CITY: BURTONSVILL

CAUSE: ROOTS EST OVERFLOW VOLUME: 95 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 309M AND 310M OVERFLOWING AT 0.5GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A TRIBUTARY OF PAINT BRANCH BASIN. THE CREW JETTED FROM 008U TO 310M A TOATL OF 272', AND HIT AND REMOVED A HARD ROOT BLOCKAGE AT 190', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

|                 |               |
|-----------------|---------------|
| DRY WEATHER     | DISCOLORATION |
| NOTICEABLE ODOR | PUBLIC ACCESS |

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

|                              |                       |
|------------------------------|-----------------------|
| MD DEPARTMENT OF ENVIRONMENT | DEP-MONTGOMERY COUNTY |
| MONTGOMERY CO MUNICIPALITIES |                       |

THE ADDRESS WAS ORIGINALLY REPORTED AS 3633 TURBRIDGE DRIVE.

SIGNS POSTED: 6 POST DATE: 10/22/2025