



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3522220-109-2025

MDE OFFICIAL CONTACTED: FELIPE

DATA CALLED IN BY: MARVIN BAILEY
12:05PM

DATE: 11/15/2025 AT

WORK ORDER(S): 3522220 3522218

EST DATE AND TIME SSO BEGAN: 11/15/2025 10:37AM DURATION: 5.83 HRS
DATE AND TIME SSO ENDED: 11/15/2025 04:27PM

SOURCE-REPAIR SEWER MAIN MH11012015 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 8205 WATERSIDE CT 20744
COUNTY/PAGE/GRID: P 5764 F06 TOWN/CITY: FORT WASHINGTON

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 350 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 015M OVERFLOWING ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 013U, AND COULD NOT PASS 50' DUE TO A POSSIBLE COLLAPSED PIPE. A WSSC CONTRACTOR SET-UP A BYPASS PUMP FROM MH013U TO 015M, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
NOTICEABLE ODOR PUBLIC ACCESS
PUBLIC USE OBSERVED DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES
PG COUNTY HEALTH DEPT

SIGNS POSTED: 2 POST DATE: 11/15/2025