



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3537000-118-2025

MDE OFFICIAL CONTACTED: KEVIN

DATA CALLED IN BY: PATRICIA A HILL DATE: 12/20/2025 AT 07:45PM

WORK ORDER(S): 3537000 3536992

EST DATE AND TIME SSO BEGAN: 12/20/2025 06:21PM DURATION: 3.32 HRS
DATE AND TIME SSO ENDED: 12/20/2025 09:40PM

SOURCE-OVERFLOWING MH MH05141135 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 3538 FISKE TER 20906
COUNTY/PAGE/GRID: M 5165 J04 TOWN/CITY: SILVER SPRING

CAUSE: WIPES EST OVERFLOW VOLUME: 100 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE #135U AND #134M HOLDING WITH SIGNS OF AN OVERFLOW ON THE PAVEMENT AROUND THE MANHOLE, AND INTO A STORM DRAIN THAT OUTFALLS INTO ROCK CREEK. THE CREW THEN JETTED FROM MANHOLE #133M TO #135U, A TOTAL OF 154', AND HIT AND RELIEVED WIPES AT 3', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER DISCOLORATION
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE VISIBLE SOLIDS REMOVED

THE CREW FLUSHED VISIBLE SOLIDS BACK INTO MANHOLE, AND WASHED DOWN THE STREET WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

SIGNS POSTED: 3 POST DATE: 12/20/2025