



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3536951-073-2025

MDE OFFICIAL CONTACTED: AMANDA GLASSMAN

DATA CALLED IN BY: BRANDON T MCCREA DATE: 12/20/2025 AT 01:30PM

WORK ORDER(S): 3536951 3536928

EST DATE AND TIME SSO BEGAN: 12/20/2025 08:14AM DURATION: 4.77 HRS
DATE AND TIME SSO ENDED: 12/20/2025 01:00PM

SOURCE-CLEAN OUT 00121454300 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 2311 SHADYSIDE AVE 20746
COUNTY/PAGE/GRID: P 5650 A03 TOWN/CITY: SUITLAND

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 572 GAL
UPON ARRIVAL, THE CREW FOUND THE PROPERTY LINE CLEANOUT OVERFLOWING APPROXIMATELY 2GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A NEABY CREEK THAT OUTFALLS INTO THE OXON RUN BASIN. THE CREW JETTED FROM MANHOLE 009M TO 010M, A TOTAL OF 319', RELIEVING A HEAVY WIPES AND GREASE OBSTRUCTION AT 15', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE LIME

THE CREW SPREAD LIME INTO THE GRASSY AREA AROUND THE MANHOLE, AND WASHED DOWN THE PAVEMENT WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 12/22/2025