



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3538296-118-2025

MDE OFFICIAL CONTACTED: JESSICA HERPEL

DATA CALLED IN BY: BRANDON T MCCREA DATE: 12/30/2025 AT 02:10PM

WORK ORDER(S): 3538296 3538280

EST DATE AND TIME SSO BEGAN: 12/30/2025 12:55PM DURATION: 3.83 HRS
DATE AND TIME SSO ENDED: 12/30/2025 04:45PM

SOURCE-OVERFLOWING MH MH07047025 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 6807 BRADLEY BLVD 20817- 3004

COUNTY/PAGE/GRID: M 5284 H10 TOWN/CITY: BETHESDA

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 460 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 025U OVERFLOWING APPROXIMATELY 2GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 024M TO 025U, A TOTAL OF 188', HITTING AND REMOVING A HEAVY BLOCKAGE OF ROOTS AND GREASE AT 110', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER	DISCOLORATION
NOTICEABLE ODOR	PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT	DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES	

ORIGINALLY REPORTED AS 9000 BLK BRADGROVE DRIVE.

SIGNS POSTED: 2 POST DATE: 12/30/2025