



# **WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT**

3542261-073-2026

MDE OFFICIAL CONTACTED: MRS. JOEANNE REPRT#183693

DATA CALLED IN BY: DIARRA K MACKALL DATE: 01/12/2026 AT 09:39PM

WORK ORDER(S): 3542261 3542029

EST DATE AND TIME SSO BEGAN: 01/12/2026 07:57PM DURATION: 1.05 HRS  
DATE AND TIME SSO ENDED: 01/12/2026 09:00PM

SOURCE-CLEAN OUT 00164463200 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 9227 LIMESTONE PL 20740  
COUNTY/PAGE/GRID: P 5287 J09 TOWN/CITY: COLLEGE PARK

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 50 GAL  
UPON ARRIVAL, THE CREW FOUND EVIDENCE OF AN OVERFLOW OF  
APPROXIMATELY 50 GALLONS AROUND THE PROPERTY LINE CLEANOUT, AND INTO  
A NEARBY STORM DRAIN THAT OUTFALLS INTO PAINT BRANCH. A WSSC  
PLUMBER SNAKE FROM THE PROPERTY LINE CLEANOUT A TOTAL OF 45', AND  
RELIEVED AN UNKNOWN BLOCKAGE AT 20', TO END THE EVENT.

## IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER	DISCOLORATION
NOTICEABLE ODOR	PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE  
CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR  
ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

## MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

RAKED AREA	VISIBLE SOLIDS REMOVED
------------	------------------------

A WSSC CREW RAKED THE AREA, AND WASHED DOWN THE AREA AROUND THE  
CLEANOUT.

## NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT	PG COUNTY HEALTH DEPT
------------------------------	-----------------------