



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3543763-118-2026

MDE OFFICIAL CONTACTED: WENDY HUANG

DATA CALLED IN BY: DON O DARKO DATE: 01/20/2026 AT 03:15PM

WORK ORDER(S): 3543763 3543740

EST DATE AND TIME SSO BEGAN: 01/20/2026 01:20PM DURATION: 2.67 HRS
DATE AND TIME SSO ENDED: 01/20/2026 04:00PM

SOURCE-OVERFLOWING MH MH14130112 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 1002 PEMBRIDGE CT 20716
COUNTY/PAGE/GRID: P 5533 D06 TOWN/CITY: MITCHELLVILLE

CAUSE: GREASE EST OVERFLOW VOLUME: 160 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 112M OVERFLOWING AT 1GPM ONTO
THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE
112M TO 111U A TOTAL OF 102', AND HIT AND RELIEVED GREASE AT 38',
TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE
CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR
ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 2 POST DATE: 01/21/2026