



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3552481-072-2026

MDE OFFICIAL CONTACTED: CHRISTY WAGNER

DATA CALLED IN BY: BRANDON T MCCREA DATE: 02/09/2026 AT 10:30AM

WORK ORDER(S): 3552481 3552420

EST DATE AND TIME SSO BEGAN: 02/09/2026 08:26AM DURATION: 7.07 HRS
DATE AND TIME SSO ENDED: 02/09/2026 03:30PM

SOURCE-GRINDER PUMP 00507358000 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 4517 HOPPER ALLEY 20841
COUNTY/PAGE/GRID: M 4928 B05 TOWN/CITY: BOYDS

CAUSE: OTHER EST OVERFLOW VOLUME: 424 GAL

UPON ARRIVAL, THE CREW FOUND A LEAK ON A VALVE FOR A PRESSURE SEWER AT THE CUSTOMERS PROPERTY LINE. A VOLUME OF 1 GPM ENTERED A STORM DRAIN THAT OUTFALLS INTO SENECA CREEK. THE PROPERTY IS NEWLY CONSTRUCTED AND IS STILL UNDER WARRENTY FROM THE BUILDER. THE BUILDERS CONTRACTOR REPAIRED THE LEAK, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION	NOTICEABLE ODOR
WET WEATHER	PUBLIC ACCESS
PUBLIC USE OBSERVED	

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THIS EVENT OCCURRED FROM A PRESSURE SEWER AND IS THEREFORE NOT
CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT	DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES	

SIGNS POSTED: 1 POST DATE: 02/09/2026