WASHINGTON SUBURBAN SANITARY COMMISSION
SANITARY SEWER OVERFLOW WRITTEN REPORT

3553383-071-2026

MDE OFFICIAL CONTACTED: JOSE GOMEZ

DATA CALLED IN BY: PAUL A DUMAS DATE: 02/12/2026 AT 08:00PM

WORK ORDER(S): 3553383

EST DATE AND TIME SSO BEGAN: 02/12/2026 09:30AM DURATION: 0.17 HRS
DATE AND TIME SSO ENDED: 02/12/2026 09:40AM

SOURCE-FACILITY 00237811500 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 514 W TANTALLON DR 20744
COUNTY/PAGE/GRID: P 5880 H05 TOWN/CITY: FORT WASHINGTON

CAUSE: OTHER EST OVERFLOW VOLUME: 1,000 GAL
A PUMP WATCH CREW AT THE SWAN CREEK WWPS OBSERVERD A DISCHARGE HOSE ON A BYPASS PUMP RUPTURE AND SPILL APPROXIMATELY 1,000 GALLONS OF SEWAGE ONTO THE GRASSY AREA AROUND THE PUMP AND INTO SWAN CREEK. THE WWPS IS CURRENTLY OUT OF SERVICE WHILE UNDERGOING REPAIRS. THE CREW SHUT DOWN THE BYPASS PUMP, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THIS EVENT OCCURRED FROM A BYPASS HOSE, AND IS THEREFORE NOT CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE DISCHARGE HOSE AND REMOVED ALL SOLIDS ROM THE AREA.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 02/13/2026