



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3554315-075-2026

MDE OFFICIAL CONTACTED: MR. CORROLL NO#GIVEN

DATA CALLED IN BY: DIARRA K MACKALL DATE: 02/18/2026 AT 12:36PM

WORK ORDER(S): 3554315

EST DATE AND TIME SSO BEGAN: 02/18/2026 12:00PM DURATION: 11.50 HRS  
DATE AND TIME SSO ENDED: 02/18/2026 11:30PM

SOURCE-AIR REL VLV/FORCE M SS29001096 WATER BODY AFFECTED-PATUXENT RIVER

CLOSEST STREET ADDRESS: 15700 ERWIN CT 20716  
COUNTY/PAGE/GRID: P 5413 D09 TOWN/CITY: MITCHELLVILLE

CAUSE:UNKNOWN EST OVERFLOW VOLUME: 1,380 GAL  
UPON ARRIVAL, THE CREW DISCOVERED A BREAK IN A 16" PRESSURE  
SEWER. THE CREW EXCAVATED AT THE BREAK, SHORED THE EXCAVATION  
AND BEGAN OVERPUMP OPERATIONS TO DIVERT THE SEWAGE TO THE  
NEAREST GRAVITY MAIN, TO END THE EVENT. NO WATERWAYS WERE  
AFFECTED BY THIS EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THIS EVENT OCCURRED ON A PRESSURE SEWER AND IS THEREFORE NOT  
CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE BROKEN PRESSURE  
SEWER.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 15700 ERWIN COURT RW3.

SIGNS POSTED: 18 POST DATE: 02/18/2026