



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3560188-073-2026

MDE OFFICIAL CONTACTED: JOSE GOMEZ

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 03/09/2026 AT 06:47PM

WORK ORDER(S): 3560188 3560176

EST DATE AND TIME SSO BEGAN: 03/09/2026 05:37PM DURATION: 3.88 HRS
DATE AND TIME SSO ENDED: 03/09/2026 09:30PM

SOURCE-CLEAN OUT 00338504400 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 4501 AUTH PL 20746
COUNTY/PAGE/GRID: P 5650 C08 TOWN/CITY: SUITLAND

CAUSE: ROOTS AND WIPES EST OVERFLOW VOLUME: 116 GAL
UPON ARRIVAL, THE CREW FOUND EVIDENCE THE PROPERTY LINE CLEANOUT HAD
OVERFLOWED ONTO ASPHALT. MANHOLE 063M WAS HOLDING BUT NOT OVERFLOWING.
THE CREW JETTED FROM MANHOLE 062M TO 063M, A TOTAL OF 299', AND HIT
AND RELIEVED HEAVY ROOTS AND WIPES AT 299', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE CREW WASHED DOWN THE ASPHALT PARKING LOT WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY
MUNICIPALITIES PG COUNTY HEALTH DEPT

SIGNS POSTED: 2 POST DATE: 03/10/2026