



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3561835-118-2026

MDE OFFICIAL CONTACTED: CHRISTY WAGNER

DATA CALLED IN BY: RASHAD S HAMEED DATE: 03/17/2026 AT 03:14PM

WORK ORDER(S): 3561835 3561796

EST DATE AND TIME SSO BEGAN: 03/17/2026 12:15PM DURATION: 8.25 HRS
DATE AND TIME SSO ENDED: 03/17/2026 08:30PM

SOURCE-OVERFLOWING MH MH04007081 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 2014 FRONTIER CT 20744
COUNTY/PAGE/GRID: P 5881 E02 TOWN/CITY: FORT WASHINGTON

CAUSE: DEBRIS EST OVERFLOW VOLUME: 2,475 GAL
DURING THE WSSC CONTRACTOR TRUNK WALK, THE CONTRACTOR FOUND MANHOLE 081U OVERFLOWING APPROXIMATELY 5 GPM ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO TINKERS CREEK IN THE PISCATAWAY BASIN. A LARGE TREE HAD FALLEN ON MANHOLE 081U, CAUSING THE OVERFLOW. A WSSC CREW JETTED FROM MANHOLE 080M TO 081U BUT WAS UNABLE TO RELIEVE THE BLOCKAGE. A WSSC CONTRACTOR SET UP BYPASS PUMPING OPERATIONS, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME
THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 10415 OUTLOOK CT.

SIGNS POSTED: 4 POST DATE: 03/17/2026