

| Potomac Filtration Plant (Q1_Monitoring)   |  |                  |                                    |
|--|--|------------------|------------------------------------|
| Sample date  | Per- and polyfluoroalkyl substances (PFAS)                         | Result (ppt)     | MCL/Health Reference Levels        |
| January, 2026  | 11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | not detected     | n/a <sup>1</sup>                   |
|  | 9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)    | not detected     | n/a <sup>1</sup>                   |
|  | 4,8-dioxa-3H-perfluorononanoic acid (ADONA)                        | not detected     | n/a <sup>1</sup>                   |
|  | hexafluoropropylene oxide dimer acid (HFPO DA)                     | not detected     | 10 ppt (MCL)                       |
|  | nonafluoro-3,6-dioxaheptanoic acid (NFDHA)                         | not detected     | n/a <sup>1</sup>                   |
|  | perfluorobutanoic acid (PFBA)                                      | 2.8              | 7,000 ppt <sup>5</sup>             |
|  | perfluorobutanesulfonic acid (PFBS)                                | 1.9              | 420 -2,100 ppt <sup>2</sup>        |
|  | 1H,1H, 2H, 2H-perfluorodecane sulfonic acid (8:2FTS)               | not detected     | n/a <sup>1</sup>                   |
|  | perfluorodecanoic acid (PFDA)                                      | not detected     | <20 ppt <sup>3</sup>               |
|  | perfluorododecanoic acid (PFDoA)                                   | not detected     | n/a <sup>1</sup>                   |
|  | perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)                   | not detected     | n/a <sup>1</sup>                   |
|  | perfluoroheptanesulfonic acid (PFHpS)                              | not detected     | n/a <sup>1</sup>                   |
|  | perfluoroheptanoic acid (PFHpA)                                    | <1.7             | <20 ppt <sup>3</sup>               |
|  | 1H,1H, 2H, 2H-perfluorohexane sulfonic acid (4:2FTS)               | not detected     | n/a <sup>1</sup>                   |
|  | perfluorohexanesulfonic acid (PFHxS)                               | <1.7             | 10 ppt (MCL)                       |
|  | perfluorohexanoic acid (PFHxA)                                     | 3.5              | 400,000 - 560,000 ppt <sup>4</sup> |
|  | perfluoro-3-methoxypropanoic acid (PFMPA)                          | not detected     | n/a <sup>1</sup>                   |
|  | perfluoro-4-methoxybutanoic acid (PFMBA)                           | not detected     | n/a <sup>1</sup>                   |
|  | perfluorononanoic acid (PFNA)                                      | not detected     | 10 ppt (MCL)                       |
|  | 1H,1H, 2H, 2H-perfluorooctane sulfonic acid (6:2FTS)               | not detected     | n/a <sup>1</sup>                   |
|  | perfluorooctanesulfonic acid (PFOS)                                | 2.2              | 4 ppt (MCL)                        |
|  | perfluorooctanoic acid (PFOA)                                      | 1.9              | 4 ppt (MCL)                        |
|  | perfluoropentanoic acid (PFPeA)                                    | 4.7              | n/a <sup>1</sup>                   |
|  | perfluoropentanesulfonic acid (PFPeS)                              | not detected     | n/a <sup>1</sup>                   |
|  | perfluoroundecanoic acid (PFUnA)                                   | not detected     | n/a <sup>1</sup>                   |
|  | N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)           | not detected     | n/a <sup>1</sup>                   |
|  | N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)          | not detected     | n/a <sup>1</sup>                   |
| perfluorotetradecanoic acid (PFTA)   | not detected   | n/a <sup>1</sup> |                                    |
| perfluorotridecanoic acid (PFTrDA)   | not detected   | n/a <sup>1</sup> |                                    |
| Hazard Index = ( [HFPO-DAppt] / [10ppt] ) + ( [PFBSppt] / [2000ppt] ) + ( [PFNAppt] / [10ppt] ) + ( [PFHxSppt] / [10.0ppt] ) | 0  | <1               |                                    |
| Lithium  | not detected   | n/a <sup>1</sup> |                                    |

#### Definitions

ppt = parts per trillion. One part per trillion is equivalent to one drop of water in 20 olympic-sized swimming pools

Not Detected : A compound is either not present or present at such low concentrations that it cannot be accurately detected by the analytical method.

MCL : maximum contamination limit

Hazard Index = ( [HFPO-DAppt] / [10ppt] ) + ( [PFBSppt] / [2000ppt] ) + ( [PFNAppt] / [10ppt] ) + ( [PFHxSppt] / [10.0ppt] ) The Hazard Index (HI) is made up of a sum of fractions. Each fraction compares the

#### Footnotes

<sup>1</sup> n/a = not applicable. There are no accepted federal standards for these compounds

<sup>2</sup> Michigan MCL of 420 ppt and 2,100 ppt Ohio EPA Action Level

<sup>3</sup> Massachusetts MCL for the sum of the six PFAS compounds known as PFAS-6

<sup>4</sup> Michigan MCL 400,000 ppt to 560,000 ppt Illinois health advisory level

<sup>5</sup> Minnesota guidance value of 7,000 ppt

| Patuxent Filtration Plant (Q1_Monitoring)  |  |                  |                                    |
|--|--|------------------|------------------------------------|
| Sample date  | Per- and polyfluoroalkyl substances (PFAS)                         | Result (ppt)     | MCL/Health Reference Levels        |
| January, 2026  | 11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | not detected     | n/a <sup>1</sup>                   |
|  | 9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)    | not detected     | n/a <sup>1</sup>                   |
|  | 4,8-dioxa-3H-perfluorononanoic acid (ADONA)                        | not detected     | n/a <sup>1</sup>                   |
|  | hexafluoropropylene oxide dimer acid (HFPO DA)                     | not detected     | 10 ppt (MCL)                       |
|  | nonafluoro-3,6-dioxaheptanoic acid (NFDHA)                         | not detected     | n/a <sup>1</sup>                   |
|  | perfluorobutanoic acid (PFBA)                                      | 2.1              | 7,000 ppt <sup>5</sup>             |
|  | perfluorobutanesulfonic acid (PFBS)                                | 1.7              | 420 -2,100 ppt <sup>2</sup>        |
|  | 1H,1H, 2H, 2H-perfluorodecane sulfonic acid (8:2FTS)               | not detected     | n/a <sup>1</sup>                   |
|  | perfluorodecanoic acid (PFDA)                                      | not detected     | <20 ppt <sup>3</sup>               |
|  | perfluorododecanoic acid (PFDoA)                                   | not detected     | n/a <sup>1</sup>                   |
|  | perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)                   | not detected     | n/a <sup>1</sup>                   |
|  | perfluoroheptanesulfonic acid (PFHpS)                              | not detected     | n/a <sup>1</sup>                   |
|  | perfluoroheptanoic acid (PFHpA)                                    | <1.6             | <20 ppt <sup>3</sup>               |
|  | 1H,1H, 2H, 2H-perfluorohexane sulfonic acid (4:2FTS)               | not detected     | n/a <sup>1</sup>                   |
|  | perfluorohexanesulfonic acid (PFHxS)                               | <1.6             | 10 ppt (MCL)                       |
|  | perfluorohexanoic acid (PFHxA)                                     | 2.4              | 400,000 - 560,000 ppt <sup>4</sup> |
|  | perfluoro-3-methoxypropanoic acid (PFMPA)                          | not detected     | n/a <sup>1</sup>                   |
|  | perfluoro-4-methoxybutanoic acid (PFMBA)                           | not detected     | n/a <sup>1</sup>                   |
|  | perfluorononanoic acid (PFNA)                                      | not detected     | 10 ppt (MCL)                       |
|  | 1H,1H, 2H, 2H-perfluorooctane sulfonic acid (6:2FTS)               | not detected     | n/a <sup>1</sup>                   |
|  | perfluorooctanesulfonic acid (PFOS)                                | <1.6             | 4 ppt (MCL)                        |
|  | perfluorooctanoic acid (PFOA)                                      | 2                | 4 ppt (MCL)                        |
|  | perfluoropentanoic acid (PFPeA)                                    | 2.5              | n/a <sup>1</sup>                   |
|  | perfluoropentanesulfonic acid (PFPeS)                              | not detected     | n/a <sup>1</sup>                   |
|  | perfluoroundecanoic acid (PFUnA)                                   | not detected     | n/a <sup>1</sup>                   |
|  | N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)           | not detected     | n/a <sup>1</sup>                   |
| N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)  | not detected   | n/a <sup>1</sup> |                                    |
| perfluorotetradecanoic acid (PFTA)   | not detected   | n/a <sup>1</sup> |                                    |
| perfluorotridecanoic acid (PFTrDA)   | not detected   | n/a <sup>1</sup> |                                    |
| Hazard Index = ( [HFPO-DAppt] / [10ppt] ) + ( [PFBSppt] / [2000ppt] ) + ( [PFNAppt] / [10ppt] ) + ( [PFHxSppt] / [10.0ppt] ) | 0  | <1               |                                    |
| Lithium  | not detected   | n/a <sup>1</sup> |                                    |

#### Definitions

ppt = parts per trillion. One part per trillion is equivalent to one drop of water in 20 olympic-sized swimming pools

Not Detected : A compound is either not present or present at such low concentrations that it cannot be accurately detected by the analytical method.

MCL : maximum contamination limit

Hazard Index = ( [HFPO-DAppt] / [10ppt] ) + ( [PFBSppt] / [2000ppt] ) + ( [PFNAppt] / [10ppt] ) + ( [PFHxSppt] / [10.0ppt] ) The Hazard Index (HI) is made up of a sum of fractions. Each fraction compares the

#### Footnotes

<sup>1</sup> n/a = not applicable. There are no accepted federal standards for these compounds

<sup>2</sup> Michigan MCL of 420 ppt and 2,100 ppt Ohio EPA Action Level

<sup>3</sup> Massachusetts MCL for the sum of the six PFAS compounds known as PFAS-6

<sup>4</sup> Michigan MCL 400,000 ppt to 560,000 ppt Illinois health advisory level

<sup>5</sup> Minnesota guidance value of 7,000 ppt