



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3576118-118-2026

MDE OFFICIAL CONTACTED: AMANDA GLASSMAN

DATA CALLED IN BY: MARGARET K CEASAR

DATE: 04/22/2026 AT 07:07PM

WORK ORDER(S): 3576118 3576117

EST DATE AND TIME SSO BEGAN: 04/22/2026 03:47PM DURATION: 1.72 HRS

DATE AND TIME SSO ENDED: 04/22/2026 05:30PM

SOURCE-OVERFLOWING MH MH14011109 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 9010 FAIRHAVEN AVE 20772

COUNTY/PAGE/GRID: P 5768 D08 TOWN/CITY: UPPER MARLBORO

CAUSE: DEBRIS

EST OVERFLOW VOLUME: 103 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 109M OVERFLOWING APPROXIMATELY 1GPM ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO AN UNKNOWN TRIBUTARY IN THE WESTERN BRANCH BASIN. THE CREW JETTED FROM MANHOLE 110M TO 013U, A TOTAL OF 230', RELIEVING A HEAVY SLUDGE AND GRAVEL OBSTRUCTION, AT 170', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

DISCOLORATION

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2

POST DATE: 04/22/2026