



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3576115-109-2026

MDE OFFICIAL CONTACTED: JULIO

DATA CALLED IN BY: KRISTIN LOELLEN BROWN DATE: 04/22/2026 AT 07:53PM

WORK ORDER(S): 3576115

EST DATE AND TIME SSO BEGAN: 04/22/2026 10:00AM DURATION: 8.00 HRS
DATE AND TIME SSO ENDED: 04/22/2026 06:00PM

SOURCE-REPAIR SEWER MAIN SS07065008 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 8910 BRADLEY BLVD 20817-2635
COUNTY/PAGE/GRID: M 5406 B01 TOWN/CITY: BETHESDA

CAUSE: DEFECTIVE MATERIAL EST OVERFLOW VOLUME: 480 GAL
DURING AN OVERPUMP FAILURE, MANHOLE 009M BEGAN TO FILL WITH SEWAGE AND CREATED HEAD PRESSURE IN THE MAINLINE. SEWAGE SEEPED OUT OF THE PIPE AND INTO A POND ON THE PROPERTY. THE CREW THEN EXTENDED THE BYPASS PUMPS TO THE UPSTREAM MANHOLE, AND ADDED AN ADDITIONAL PUMP FOR BACK-UP, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THIS LINE IS CURRENTLY ON BYPASS AND CAN NOT BE CCTV'D AT THIS TIME.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 7 POST DATE: 04/22/2026