



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3577026-073-2026

MDE OFFICIAL CONTACTED: CRISTIE WAGNER

DATA CALLED IN BY: MARVIN BAILEY DATE: 04/23/2026 AT 01:45PM

WORK ORDER(S): 3577026 3576932

EST DATE AND TIME SSO BEGAN: 04/23/2026 08:05AM DURATION: 2.92 HRS
DATE AND TIME SSO ENDED: 04/23/2026 11:00AM

SOURCE-CLEAN OUT 00401151600 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 931 CASLON WAY 20785
COUNTY/PAGE/GRID: P 5531 C06 TOWN/CITY: HYATTSVILLE

CAUSE: TAMPERING EST OVERFLOW VOLUME: 175 GAL
UPON ARRIVAL, THE CREW FOUND THE PROPERTY LINE CLEANOUT OVERFLOWING APPROXIMATELY 1GPM, ONTO THE GRASSY AREA AROUND THE CLEANOUT AND INTO A NEABY STORM DRAIN THAT OUTFALLS IN THE WESTERN BRANCH BASIN. THE CREW JETTED FROM MANHOLE 383M, A TOTAL OF 26', REMOVING A CHAIR LEG AND A PIECE OF PVC PIPE AT 11', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
PUBLIC ACCESS PUBLIC USE OBSERVED
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE CLEANOUT.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES NO STIPULATED PENALTY

WSSC POLICE DEPARTMENT 04/24/26 @ 8:00AM

SIGNS POSTED: 1 POST DATE: 04/24/2026