



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3578116-073-2026

MDE OFFICIAL CONTACTED: KRISTY WAGNER

DATA CALLED IN BY: MARK ALEXANDER DATE: 04/29/2026 AT 02:28PM

WORK ORDER(S): 3578116 3577967

EST DATE AND TIME SSO BEGAN: 04/28/2026 09:09PM DURATION: 1.85 HRS
DATE AND TIME SSO ENDED: 04/28/2026 11:00PM

SOURCE-CLEAN OUT ACCT# 00382493500 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 6749 ALLENTOWN RD 20748
COUNTY/PAGE/GRID: P 5766 D03 TOWN/CITY: TEMPLE HILLS

CAUSE: ROOTS EST OVERFLOW VOLUME: 56 GAL
UPON ARRIVAL, THE CREW FOUND THE CLEANOUT AT THE PROPERTY LINE WITH EVIDENCE OF AN OVERFLOW TOTALING 56 GALLONS. THE CREW SNAKED A TOTAL OF 60' AND RELIEVED ROOTS AT 55', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE CLEANOUT.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES