



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3578006-118-2026

MDE OFFICIAL CONTACTED: CHUCK RAY

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 04/29/2026 AT 03:27PM

WORK ORDER(S): 3578006 3577997

EST DATE AND TIME SSO BEGAN: 04/29/2026 08:43AM DURATION: 3.20 HRS

DATE AND TIME SSO ENDED: 04/29/2026 11:55AM

SOURCE-OVERFLOWING MH MH29005021 WATER BODY AFFECTED-PATUXENT RIVER

CLOSEST STREET ADDRESS: 3836 EARLY GLOW LN 20716

COUNTY/PAGE/GRID: P 5413 D10 TOWN/CITY: BOWIE

CAUSE: ROOTS & GREASE

EST OVERFLOW VOLUME: 192 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 021N OVERFLOWING AT 3 GPM INTO A NEARBY STORM DRAIN THAT OUTFALLS INTO PATUXENT CENTER. THE CREW JETTED FROM MANHOLE 012U TO MANHOLE 014M A TOTAL OF 129' AND RELIEVED ROOTS AND GREASE AT 116', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 04/30/2026