



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3584373-118-2026

MDE OFFICIAL CONTACTED: MS.RYAN REPORT#188924

DATA CALLED IN BY: DIARRA K MACKALL DATE: 05/04/2026 AT 05:18PM

WORK ORDER(S): 3584373 3584359

EST DATE AND TIME SSO BEGAN: 05/04/2026 03:28PM DURATION: 2.50 HRS
DATE AND TIME SSO ENDED: 05/04/2026 05:58PM

SOURCE-OVERFLOWING MH MH14092062 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 2000 OVERTON DR 20747
COUNTY/PAGE/GRID: P 5651 B03 TOWN/CITY: FORESTVILLE

CAUSE: DEBRIS EST OVERFLOW VOLUME: 150 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 062M OVERFLOWING APPROXIMATELY 1 GPM ONTO THE SURROUNDING ASPHALT, AND INTO A NEARBY STORM DRAIN IN THE WESTERN BRANCH BASIN. THE CREW JETTED FROM MANHOLE 050U TO 062M, A TOTAL OF 146', AND RELIEVED A GRAVEL OBSTRUCTION, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

| | |
|---------------------|---------------|
| DRY WEATHER | DISCOLORATION |
| NOTICEABLE ODOR | PUBLIC ACCESS |
| PUBLIC USE OBSERVED | |

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE CREW DISINFECTED AND WASHED DOWN THE AFFECTED AREA WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:

| | |
|------------------------------|--------------------------|
| MD DEPARTMENT OF ENVIRONMENT | PG COUNTY MUNICIPALITIES |
| PG COUNTY HEALTH DEPT | |

SIGNS POSTED: 1 POST DATE: 05/04/2026