



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3594493-118-2026

MDE OFFICIAL CONTACTED: CHRISTY FERGUSON

DATA CALLED IN BY: BRANDON T MCCREA DATE: 06/08/2026 AT 01:20PM

WORK ORDER(S): 3594493 3594449

EST DATE AND TIME SSO BEGAN: 06/08/2026 10:16AM DURATION: 1.45 HRS  
DATE AND TIME SSO ENDED: 06/08/2026 11:43AM

SOURCE-OVERFLOWING MH SS14036094 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 10208 WELSHIRE DR 20772  
COUNTY/PAGE/GRID: P 5767 H01 TOWN/CITY: UPPER MARLBORO

CAUSE: GREASE EST OVERFLOW VOLUME: 87 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 094M OVERFLOWING AT 1GPM ONTO  
THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE  
093U TO 094M, A TOTAL OF 63' AND HIT AND RELIEVED A HEAVY GREASE  
BLOCKAGE AT 63', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE  
CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR  
ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME  
THE CREW SPREAD LIME.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 06/08/2026