



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3595780-118-2026

MDE OFFICIAL CONTACTED: KRISTIE WAGNER

DATA CALLED IN BY: MARVIN BAILEY

DATE: 06/12/2026 AT 02:20PM

WORK ORDER(S): 3595780 3595748

EST DATE AND TIME SSO BEGAN: 06/12/2026 10:30AM DURATION: 3.00 HRS
DATE AND TIME SSO ENDED: 06/12/2026 01:30PM

SOURCE-OVERFLOWING MH MH10055053 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 2304 MUSKOGEE ST 20783
COUNTY/PAGE/GRID: P 5287 F08 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 900 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 053M OVERFLOWING APPROXIMATELY
5 GPM, ENTERING A NEARBY STORM DRAIN THAT OUTFALLS INTO NORTHWEST
BRANCH. THE CREW JETTED FROM MANHOLES 028U AND 053M, A TOTAL OF 156',
AND HIT AND RELIEVED GREASE AND WIPES AT 156', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE
CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE LIME

THE CREW SPREAD LIME AROUND THE AFFECTED AREA.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 06/12/2026