


NOTES:

1. RESTRAIN ALL JOINTS ON 6" BLOWOFF PIPING, SEE SPECIFICATIONS
2. SET VALVE BOX AND MANHOLE RIM TO FINISHED GRADE OR AS SHOWN ON THE DRAWINGS.
3. MANHOLE SHALL BE LOCATED AS SHOWN UNLESS OTHERWISE INDICATED ON THE DRAWINGS.
4. SEE DETAIL W/2.8 FOR V-BIO POLYETHYLENE ENCASEMENT AT MANHOLE INTERFACE.

WASHINGTON SUBURBAN SANITARY COMMISSION	APPROVED: <u>9/28/16</u>  Chief Engineer	STANDARD DETAIL TYPE "A" BLOWOFF FOR WATER MAINS 36-INCH AND LARGER	W <hr/> 3.02
--	---	--	-----------------