



**NOTES:**

1. RESTRAIN ALL JOINTS ON 6" BLOWOFF PIPING, SEE SPECIFICATIONS.
2. SET VALVE BOX AND MANHOLE RIM TO FINISHED GRADE OR AS SHOWN ON THE DRAWINGS.
3. MANHOLE SHALL BE LOCATED AS SHOWN UNLESS OTHERWISE INDICATED ON THE DRAWINGS.
4. SEE DETAIL W/2.8 FOR V-BIO POLYETHYLENE ENCASEMENT AT MANHOLE INTERFACE.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED:

*9/28/16*  
  
Chief Engineer

STANDARD DETAIL

TYPE "B" BLOWOFF  
FOR WATER MAINS  
36-INCH AND LARGER

W  
3.03