



**NOTES:**

1. METER SETTING FOR NON-TRAFFIC AREAS ONLY, DO NOT LOCATE IN SIDEWALK OR DRIVEWAY, UNLESS OTHERWISE NOTED ON THE DRAWINGS.
2. COMPACT BACKFILL AND AGGREGATE BASE AS STRUCTURAL FILL.
3. EXTEND COPPER SERVICE OUTLET 3'-0" MINIMUM BEYOND METER BOX OR PROPERTY LINE, WHICHEVER IS GREATER.
4. 1-1/2" SINGLE METER SETTER IS COMPLETE ONE-PIECE FACTORY ASSEMBLED, INCLUDING TWO ANGLE BALL VALVES, BENDS AND COMPRESSION CONNECTIONS.

WASHINGTON SUBURBAN SANITARY COMMISSION	APPROVED: <u>9/28/16</u>  Chief Engineer	STANDARD DETAIL  <b>1-1/2-INCH METER SETTING FOR 2-INCH SERVICE</b>	$\frac{W}{5.8}$
--------------------------------------------------	------------------------------------------------	-----------------------------------------------------------------------------------	-----------------