



	NOMINAL DIAMETER OF BRANCH						
	4"	6"	8"	10"	12"	14"	16"
L	2'-0"	3'-0"	4'-0"	6'-0"	7'-0"	8'-0"	9'-0"
H	1'-6"	2'-0"	3'-0"	3'-0"	3'-6"	4'-0"	4'-6"
T	1'-0"	1'-0"	1'-6"	2'-6"	3'-0"	3'-6"	4'-0"
F	0'-6"	0'-6"	0'-9"	0'-9"	1'-0"	1'-0"	1'-0"

NOTE:

1. SEE BLOCKING DESIGN REQUIREMENT NOTES, DETAIL B/1.0.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 8/18/16

Chief Engineer

STANDARD DETAIL
THRUST BLOCKS FOR
TEES AND TAPPING
SLEEVES

$\frac{B}{1.3}$