



**NOTES:**

1. THE TEST LEAD WIRES SHALL BE STRANDED COPPER AWG WIRE WITH TW, THW, OR THWN INSULATION. WIRE SIZE AND COLOR SHALL BE AS SHOWN.
2. RUN ALL WIRES IN 2" PVC SCH. 40 FROM THE CONNECTION POINT UNTIL THEY REACH THE BOTTOM OF TEST STATION ASSEMBLY.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED:

8/12/16

*[Signature]*

Chief Engineer

STANDARD DETAIL

TEST STATION AT  
MECHANICAL JOINT / PUSH-ON  
CAP / PLUG

C  
2.6