



NOTES:

1. TEST LEADS SHALL BE STRANDED COPPER WIRE WITH TW, THW OR THWN.
2. AFTER INSTALLATION AND ASSEMBLY, TEST INSULATING JOINT
3. FOR COATING OF INSULATING JOINT, SEE DETAIL C/3.0a.

WASHINGTON SUBURBAN SANITARY COMMISSION	APPROVED: <u>8/12/16</u> Chief Engineer	STANDARD DETAIL INSULATED FLANGE JOINT DETAIL	<table style="margin: auto; border: none;"> <tr> <td style="border: none;">C</td> </tr> <tr> <td style="border: none; border-top: 1px solid black;">3.0</td> </tr> </table>	C	3.0
C					
3.0					