


**NOTES:**

1. SEE DETAIL C/1.0 FOR BOND WIRE SIZE AND INSULATION REQUIREMENTS.
2. FOR TEST LEAD WIRE REQUIREMENTS, SEE DETAIL C/3.0 AND NOTE 1.
3. RUN ALL WIRES IN 2" PVC SCH40 CONDUIT FROM THE CONNECTION POINT UNTIL THEY REACH THE BOTTOM OF TEST STATION ASSEMBLY.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 8/12/16  
  
Chief Engineer

STANDARD DETAIL  
VALVE TO MAIN  
INSULATED FLANGE  
JOINT (UNRESTRAINED)

C  
3.2