



PCCP x DIP TIE-IN DETAIL

NOTES:

1. CONTRACTOR SHALL VERIFY ELECTRICAL ISOLATION OF INSULATING JOINT BEFORE COATING AND BURIAL.
2. DO NOT INSTALL TEST LEAD WIRES AND REFERENCE CELL.
3. APPLICABLE MANUFACTURERS' RECOMMENDATIONS SHALL BE FOLLOWED FOR INSTALLATION OF ADAPTER AND INSULATING FLANGE ASSEMBLIES.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED:

8/12/16
[Signature]
Chief Engineer

STANDARD DETAIL

PCCP x DIP
TIE - IN DETAIL
WITH INSULATING JOINT

C
3.3