


NOTES:

1. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE, SEE DETAIL C/7.13.
2. DO NOT THERMITE WELD TO PVC PIPE.

WASHINGTON SUBURBAN SANITARY COMMISSION	APPROVED: <u>9/27/16</u>  Chief Engineer	STANDARD DETAIL PVC AWWA C-900 PIPE 12-INCH ANODE PROTECTION VALVE	$\frac{C}{7.1}$
--	---	---	-----------------