


NOTES:

1. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE, SEE DETAIL C/7.13.
2. DO NOT THERMITE WELD TO PVC PIPE.

WASHINGTON SUBURBAN SANITARY COMMISSION	APPROVED: <u>9/29/16</u>  Chief Engineer	STANDARD DETAIL PVC AWWA C-900 PIPE 4-INCH TO 12-INCH ANODE PROTECTION FOR MJ SOLID SLEEVE	$\frac{C}{7.7}$
--	---	--	-----------------