


**NOTES:**

1. BACKFILL ANODES WITH NATIVE SOIL FOR A MINIMUM OF 12 INCHES ON ALL SIDES. DO NOT BACKFILL ANODES WITH SAND OR STONE.
2. DO NOT THERMITE WELD TO PVC PIPE.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 9/29/16  
  
Chief Engineer

STANDARD DETAIL  
PVC AWWA C-900 PIPE  
4-INCH TO 12-INCH  
SINGLE ANODE PLACEMENT

C  
7.12