



### ELEVATION AND FITTING SCHEDULE

A	PRESSURE SEWER INFLUENT INVERT ELEVATION
B	GRAVITY SEWER INVERT ELEVATION
C	WEIR TOP ELEVATION 1" HIGHER THAN CROWN OF PRESSURE SEWER
D	P.V.C. BELL-END SECTION-4" MINIMUM SIZE
E	P.V.C. NIPPLE-4"
F	P.V.C. REDUCERS-INCREASE TO 4"
G	P.V.C. PRESSURE SEWER

#### NOTE:

1. SEE DETAIL PS/4.0 FOR PLAN VIEW.
2. FOR D.I.P. SEWER, SEE SPECIFICATIONS FOR SPECIAL INTERIOR LININGS.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED:

*8/18/16*  
  
Chief Engineer

STANDARD DETAIL  
TRANSITION MANHOLE  
SECTION A-A

PS  
4.1